

**State of California
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles**

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
KINDER MORGAN LIQUIDS TERMINALS, LLC
NPDES NO. CAG674001
CI-8377**

PROJECT LOCATION

Gaffey Street Terminal
1363 N. Gaffey Street
San Pedro, CA 90731

FACILITY MAILING ADDRESS

1100 Town & Country Road
Orange, CA 92868
Contact: Mr. Ron Zinner

PROJECT DESCRIPTION

Kinder Morgan Liquids Terminal, LLC (herein after Kinder Morgan) proposes to perform a hydrostatic testing of storage tank no. GT-45001 after cleaning and repairing of the tank located at 1363 N. Gaffey Street in San Pedro. The capacity of the tank is 1.89 million gallons. The hydrostatic test will be performed using municipal water from the City.

VOLUME AND DESCRIPTION OF DISCHARGE

Kinder Morgan proposes to discharge up to 1.764 million gallons of wastewater during the hydrostatic testing. If chlorine is present in the wastewater, sodium thiosulfate chemical injection system will be utilized to mitigate the chlorine prior to discharge. The wastewater will be discharged to the storm drain (Outfall No. 001) located on site (Latitude 33° 45' 35", Longitude 118° 17' 40"). The discharge will flow directly to West Basin of Los Angeles Inner Harbor (Dominguez Channel Watershed), a water of the United States. See Figure 1 for site location and Figure 2 for a flow diagram.

FREQUENCY OF DISCHARGE

The discharge will be continuous and will last for about one week. The discharge is proposed to begin in March 2002.

REUSE OF WATER

Use of dust control was considered as a viable reuse alternative at the site. However, it is not feasible because of the high flow rate and the limited area requiring dust control. Therefore, the wastewater will be discharged to the Harbor.